



VOLUME REQUIRED:

1 CU. FT. OF SEEPAGE PIT  
FOR EVERY 1.9 SQ. FT.  
OF IMPERVIOUS AREA

\* TOP 12" OF STONE MAY  
BE 3/4" IN SIZE TO AID IN  
PIPE INSTALLATION

**DETAIL**  
**TYP. ROOF DRAIN SEEPAGE PIT**

SCALE: NONE

TRENCH SHALL BE LINED WITH PADOT CLASS 1 GEOTEXTILE MATERIAL PER PUBLICATION 408, SECTION 212.36. ALLOW 1' OVERLAP ACROSS BACKFILL AT TOP OF TRENCH AND ALSO AN OVERLAP OF 1' AT END OF ROLLS.

ALL DWELLINGS MUST UTILIZE ROOF DRAIN SEEPAGE PITS. A PERC TEST BY THE ZONING OFFICER MAY BE REQUIRED.